



St	STORM DRAIN OUTLET PROTECTION GA. STD. 1125 & 2332 	A PIPE OR BOX CULVERT OUTLET HEADWALL WITH AN APRON AND DISSIPATOR BLOCKS IS USED TO PREVENT EROSION AND TO SLOW WATER. IT IS USED ON THE OUTLET OF ALL BOX CULVERTS AND ON 48" AND LARGER PIPES. MAY BE USED ON INLET FOR FLOWING STREAMS. USE ON SMALL PIPES WHEN OUTLET VELOCITY IS 12 fps AND GREATER.
	LINE CODE 	
St-Rd	STORM DRAIN OUTLET PROTECTION SECTION 603 	THIS ITEM IS ADDED TO "St" WHEN ADDITIONAL PROTECTION IS NEEDED. TYPE 1 RIP RAP PLACED ON FILTER FABRIC SHOULD BE USED AT A 24" THICKNESS. MAY BE USED ON INLETS FOR FLOWING STREAMS. REFER TO CHARTS IN "MANUAL FOR EROSION AND SEDIMENT CONTROL IN GEORGIA" FOR QUANTITIY DETERMINATION.
	PATTERN 	
Su	SURFACE ROUGHENING SERRATED SLOPES CONSTRUCTION DETAIL SECTION 205 	PROVIDING A ROUGH SOIL SURFACE WITH HORIZONTAL DEPRESSIONS. BY OPERATING A CLEATED DOZER ON THE SLOPE IN A VERTICAL DIRECTION. CREATING SERRATED SLOPES IN THE GRADING PROCESS TO CONSTRUCT BENCHES WILL REDUCE RUNOFF VELOCITY AND INCREASE INFILTRATION OF WATER. IN MOST CASES THIS ITEM IS NOT REQUIRED TO BE SHOWN ON THE PLANS, BUT REQUIRED TO BE COMPLETED BY THE CONTRACTOR UNDER ALL PROJECTS. IF SERRATED SLOPES ARE USED ON THE PROJECT, THEN THIS ITEM SHALL BE SHOWN WHERE SERRATED SLOPES ARE TO BE USED.
	LINE CODE  (LINE CODE Su IS SHOWN ON THE PLANS FOR SERRATED SLOPES WHERE SPECIFIED IN THE SOIL SURVEY.)	

NOTE:
 1. DO NOT USE EROSION CONTROL ITEMS IN A FLOWING STREAM OR IN A TIDAL AREA BELOW HIGH TIDE.
 2. FOR ADDITIONAL INFORMATION ON THE DESIGN AND APPLICATION OF EROSION CONTROL MEASURES SEE THE GEORGIA SOIL AND WATER CONSERVATION COMMISSION, "MANUAL FOR EROSION AND SEDIMENT CONTROL IN GEORGIA".

	DATE	DEPARTMENT OF TRANSPORTATION STATE OF GEORGIA	
	REVISION	EROSION CONTROL LEGEND AND UNIFORM CODE SHEET SHEET 6 OF 6	
		NO SCALE	NOV., 2007
	BY	NUMBER EC-L6	DRAWING No. 52-6

GSWCC LEVEL II DESIGN PROFESSIONAL NO. 0000018858

 GEORGIA LICENSED PROFESSIONAL
 2-25-10
 DATE



**JORDAN
JONES &
GOULDING**

REVISION DATES		
NO.	DATE	DESCRIPTION

TOWN OF BRASELTON

OFFICE:
EROSION CONTROL LEGEND

SR53 & SR124
 INTERSECTION REALIGNMENT

DRAWING No.
52-06

GSWCC LEVEL II DESIGN PROFESSIONAL NO. 0000018858
 GEORGIA LICENSED PROFESSIONAL
 2-25-10
 DATE
 JORDAN JONES & GOULDING
 1000 W. BROAD ST., SUITE 200
 ATLANTA, GA 30334
 TEL: 404.525.1000
 FAX: 404.525.1001
 WWW.JJG.COM