

NOTES:

1. SEE TOWN SPECIFICATIONS FOR APPROVED SUBMERSIBLE SEWAGE LIFT STATION.
2. OUTSIDE ELECTRICAL CONTROL CENTER PANEL, NEMA 4 ENCLOSURE MADE OF BRUSHED ALUMINUM OR STAINLESS STEEL WITH NEOPRENE GASKETS AND LOCKS.
3. FOR ALL PIPE PENETRATIONS THROUGH CONCRETE WALLS USE LINK SEAL WS PRODUCTS.
4. VAULT SHALL BE REINFORCED CONCRETE (MIN. 3000 PSI) IN ACCORDANCE WITH ASTM C 913.
5. ALL PIPING FROM PUMPS TO DISCHARGE OF VALVE VAULT TO BE FLANGED DIP.
6. WETWELL SHALL BE COATED AS PER SPECIFICATIONS—SEE SECTION 02603.
6. DETAIL AND ARRANGEMENT SHOWN AS MINIMUM GUIDELINES ONLY.
7. NOT ALL REQUIRED ITEMS ARE SHOWN.

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

JOB TITLE STANDARD DETAIL	SHEET TITLE	DRN. BY: EMI	REV. NO.	BY	DATE
	LIFT STATION DETAIL NOTES	CKD BY:			
		APPD. BY:			
		DATE: MAY 2005			
		DETAIL No. PS-2	FILE No. 03033\PS-2.dwg	SCALE: N.T.S.	