



NOTES:

1. PVC FENCE SLATS MAY BE REQUIRED AT SOME LOCATIONS AND AT THE DEVELOPERS OPTION AT OTHERS OR AS REQUIRED BY TOWN.
2. 7 GAUGE TENSION WIRES ARE REQUIRED AT THE TOP AND BOTTOM OF THE FENCE.
3. CONTRACTOR/DEVELOPER SHALL FURNISH GATE LOCK AND TWO KEYS – MASTER KEYED TO TOWN'S SYSTEM.
4. SLIDING GATES ON ROLLERS REQUIRED.

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

JOB TITLE STANDARD DETAIL	SHEET TITLE CHAIN LINK FENCE & GATE DETAIL	DRN. BY: EMI	REV. NO.	BY	DATE
		CKD BY:			
		APPD. BY:			
		DATE: SEP. 2004			
		DETAIL No. PS-6	FILE No. 03033\PS-6.dwg	SCALE: N.T.S.	