

RUBBERIZED BOOT,  
SEAL AND CLAMP

EXISTING TABLES SHALL  
BE MODIFIED AS REQUIRED

FORCE MAIN  
INLET

SLOPE

GRAVITY SEWER  
OUTLET

**DEAD END MANHOLE**

FORCE MAIN  
INLET

FLG. BELL MOUTH  
90° BEND

RUBBERIZED BOOT,  
SEAL AND CLAMP

12" MIN.

GRAVITY SEWER  
OUTLET

**MID STREAM MANHOLE**

**NOTES:**

1. EXISTING MANHOLES SHALL BE CORED FOR FORCE MAIN INSTALLATION. NO MANHOLE SHALL BE CORED WITHOUT TOWN APPROVAL AND TOWN PERSONNEL ON SITE DURING THE CORING.
2. THE MANHOLE WHERE A FORCEMAIN TIES INTO SHALL BE COATED AS PER SPECIFICATION SECTION 2602, OR 2603. THIS APPLIES TO NEW MANHOLES AS WELL AS EXISTING ONES.

**TOWN OF BRASELTON WATER & SEWER DEPARTMENTS**

JOB TITLE  STANDARD DETAIL	SHEET TITLE  <b>FORCE MAIN TO MANHOLE CONNECTION</b>	DRN. BY: EMI	REV. NO.	BY	DATE
		CKD BY:	A	EMI	3/13/07
		APPD. BY:			
		DATE: SEP. 2004			
		DETAIL No. PS-9	FILE No. 03033\PS-9.dwg	SCALE: N.T.S.	