



NOTE:

- 1) A CLEANOUT SHALL BE PLACED ON SERVICE LATERALS AT EVERY BEND.
- 2) ON STRAIGHT RUNS OF SERVICE LATERALS, CLEAN OUTS SHALL BE PLACED BETWEEN PROPERTY LINE AND HOUSE WITH SPACING NOT TO EXCEED 80'.
- 3) MINIMUM SLOPE FOR SERVICE LATERALS IS 1.00%.
- 4) LATERALS SHALL BE 6"Ø MINIMUM.

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

JOB TITLE STANDARD DETAIL	SHEET TITLE SERVICE LATERAL	DRN. BY: EMI	REV. NO.	BY	DATE
		CKD BY:	A	EMI	3/13/07
		APPD. BY:	B	EMI	1/9/09
		DATE: SEP. 2004			
		DETAIL No. S-17	FILE No. 03033\S-17.dwg	SCALE: N.T.S.	