



PLAN VIEW OF MANHOLE

NOTES:

1. A MINIMUM OF 0.2' (2/10') FALL ACROSS MANHOLE INVERT FROM INLET TO OUTLET IS REQUIRED.
2. TABLES ARE TO BE GENTLY SLOPED AND TROWELED FROM MANHOLE WALL TO INVERT WALL HEIGHT AND CONSTRUCTED OF AGGREGATE-MIX CEMENT WITH SMOOTH VENEER FINISH.
3. DEVELOPER/CONTRACTOR IS REQUIRED TO PERFORM VACUUM TESTS IN ACCORDANCE WITH SECTION 02601-MANHOLE OF THE TOWN OF BRASELTON STANDARD SPECIFICATIONS (LATEST EDITION).

SHEET 2 OF 4

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

JOB TITLE	SHEET TITLE	DRN. BY: EMI	REV. NO.	BY	DATE
		CKD BY:			
		APPD. BY:			
		DATE: SEP. 2004			
		DETAIL No. S-2	FILE No. 03033\S-2.dwg	SCALE: N.T.S.	
STANDARD DETAIL	MANHOLE INVERT				