



NOTE:

1. BEFORE ANY UTILITY IS INSTALLED, THE ENTIRE WIDTH OF THE R/W SHALL BE ROUGH GRADED AND ALL CONCRETE CURBING SET AT FINAL GRADES.
2. IN GENERAL, THE DEEPEST UTILITIES SHOULD BE INSTALLED FIRST TO MINIMIZE ANY POSSIBLE INTERFERENCE WITH LATERALS OR SERVICE LINES.
3. STREET OPENING PERMITS ARE REQUIRED BEFORE ANY COMPLETED PAVEMENT CAN BE CUT FOR ANY PURPOSE.
4. IN CUL-DE-SAC STREETS, ALL DIMENSIONS SHALL BE THE SAME AS STANDARD STREET SPACING.
5. EACH UTILITY SHALL BE RESPONSIBLE FOR REPAIR OF ANY DAMAGE TO OTHER UTILITIES, OR TO THE STREET IMPROVEMENTS WITHIN THE R/W.
6. DEVELOPER/CONTRACTOR IS REQUIRED TO PERFORM INSPECTION TESTS IN ACCORDANCE WITH SECTION 02736-SANITARY SEWER, OF THE TOWN OF BRASELTON STANDARD SPECIFICATIONS (LATEST EDITION)
7. WATER MAINS SHALL BE TOTALLY LOOPED IN CUL-DE-SACS.

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

JOB TITLE STANDARD DETAIL	SHEET TITLE UTILITY LOCATIONS WITHIN R/W	DRN. BY: EMI	REV. NO.	BY	DATE
		CKD BY:	A	EMI	3/13/07
		APPD. BY:	B	EMI	1/9/09
		DATE: SEP. 2004			
		DETAIL No. S-33	FILE No. 03033\S-33.dwg	SCALE: N.T.S.	