

SECTION 02508

GRAVEL DRIVEWAY AND ROADWAY REPAIR

PART 1 GENERAL

1.01 SCOPE OF WORK

WORK included in this section consists of repair or replacement of gravel driveways and roadways.

1.02 RELATED WORK

- A. Section 02505 – Granular Surface Paving
- B. Section 02523 – Restoring Sidewalks, Driveways, Curbs Gutters and Storm Drainage Structures

1.02 REFERENCES

Standard Specifications, Construction of Roads and Bridges, Latest Edition - Department of Transportation, State of Georgia.

PART 2 PRODUCTS

2.01 GRADED AGGREGATE BASE COURSE

Material used for graded aggregate base course shall meet requirements of the Georgia DOT Standard Specifications, Section 815.01, Group II Aggregates, latest edition.

Stone base shall be a graded aggregate conforming to the following:

Sieve Size	% Passing by Weight
2"	100
1-1/2"	97-100
3/4"	60-90
No. 10	25-45
No. 60	5-30
No. 200	0-15

PART 3 EXECUTION

3.01 GRAVEL DRIVEWAY REPAIRS

Shall conform to the requirements of Paragraph 2.01 (Graded Aggregate Base Course) of this specification.

3.02 CLEAN UP

- A. Before work shall be considered complete, remove material not used and rubbish of every character from job site.
- B. Any subsequent settlement of backfill or aggregate course shall be brought to grade.
- C. Any and all items disturbed by the construction shall in every case be restored to their original condition as closely as possible after completion of the construction.

END OF SECTION