



NOTE:

1. TOP OF METER MUST BE A MINIMUM OF 12" FROM THE TOP OF THE METER BOX.
2. CURB STOP SHALL BE LOCATED SO VALVE IS ACCESSIBLE AND CAN BE OPERATED.

TOWN OF BRASELTON WATER & SEWER DEPARTMENTS

JOB TITLE STANDARD DETAIL	SHEET TITLE 1 -INCH AND SMALLER SERVICE CONNECTION (WITH METER)	DRN. BY: EMI	REV. NO.	BY	DATE
		CKD BY:	A	EMI	3/13/07
DETAIL No. W-14		APPD. BY:			
		DATE: MARCH 2004			
		FILE No. 03033\W-14.dwg	SCALE: N.T.S.		