



**NOTE:**

1. TOP OF METER MUST BE A MINIMUM OF 12" FROM THE TOP OF THE METER BOX.
2. CURB STOP SHALL BE LOCATED SO VALVE IS ACCESSIBLE AND CAN BE OPERATED.

**TOWN OF BRASELTON WATER & SEWER DEPARTMENTS**

JOB TITLE  STANDARD DETAIL	SHEET TITLE	DRN. BY: EMI	REV. NO.	BY	DATE
	2-INCH SERVICE CONNECTION (WITH METER)	CKD BY:			
		APPD. BY:			
		DATE: JULY 2007			
DETAIL No. W-15		FILE No. 03033\W-15.dwg	SCALE: N.T.S.		